

- 3. Drawings E102.00, E103.00, E104.00 have type B lamppost calling for work as per notes #10, 14, and 22. Typical, but have no conduit connection to any handhole. Please confirm the only work at these locations is per notes #10, 14, 22. *All internal works at the pole to be completed as per notes and existing conduits from hand holes to be used. Wherever conduit to pole is not shown, contractor to trace the conduit and change power wiring.*
- 4. Are First Street [*sic*] and Little West Street considered “protected streets” as per the NYCDOT? Is a professional arborist required when excavating for conduit repairs when in the vicinity of the trees? *Neither First Place nor Little West Street is a NYC DOT protected street. Battery Place is a NYC DOT protected street and Little West Street is a NYS DOT protected street. A professional arborist is not required.*
- 5. Clarify note 14, does this refer to wiring from handhole to lineside of fuse or loadside of fuse to ballast. *This refers to the wiring from loadside of fuse to the ballast.*
- 6. Is a letter of surety required on this project? *A letter of surety is required with your proposal. The project requires a payment and performance bond in value of 100% of the project.*

By signing the line below, I am acknowledging that all pages of the addenda have been received, reviewed and understood, and will be incorporated into the bid price submitted. This document must be attached to the proposal for consideration.

Print Name	Signature	Date
Number of pages received: _____	<fill in>	

Distributed to: All present and all prospective Proposers